



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx TUR 14.0028X	issue No.:0	Certificate history:
Status:	Current		
Date of Issue:	2015-04-13	Page 1 of 3	
Applicant:	TOP HI-TECH CO.,LTD. 5F,NO.113,Zhongcheng Rd, Tucheng Dist,New Taipei City 236, Taiwan		
Electrical Apparatus: Optional accessory:	THT-EX1217**PE6*		
Type of Protection:	Ex d, Ex t		
Marking:	Ex d IIB+H2 T6...T4 Gb Ex tb IIIC T105°C Db		
Approved for issue on behalf of the IECEx Certification Body:	Dipl.-Ing. Klauspeter Graffi		
Position:	Head of Certification Body		
Signature: (for printed version)			
Date:	2015-04-13		

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

TUV Rheinland Industrie Service GmbH
Am Grauen Stein
51105 Cologne
Germany





IECEx Certificate of Conformity

Certificate No.: IECEx TUR 14.0028X

Date of Issue: 2015-04-13

Issue No.: 0

Page 2 of 3

Manufacturer: **TOP HI-TECH CO.,LTD.**
2F, No. 81, Zhongcheng Rd,
Tucheng Dist., New Taipei City 236,
Taiwan

Additional Manufacturing location
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition: 6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-1 : 2007-04 Edition: 6	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
IEC 60079-31 : 2008 Edition: 1	Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure 't'

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:
[DE/TUR/ExTR14.0038/00](#)

Quality Assessment Report:
[DE/TUR/QAR13.0016/00](#)



IECEx Certificate of Conformity

Certificate No.: IECEx TUR 14.0028X

Date of Issue: 2015-04-13

Issue No.: 0

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

Subject and type

Universal Explosion Proof LED Lighting type THT-EX1217**PE6*
(For description of type code see attachment)

Description

The lamp Universal Explosion Proof LED Lighting type THT-EX1217**PE6* is suitable for hazardous area zone 1, zone 2, zone 21 and zone 22.

The lamp has metallic enclosure with a coating on it. The method of lamp install included hanging/ceiling/wall, stanchion 25°C/90°C and pendant. The external earthing of enclosure is considered.

Parameters

Electrical parameters

Rated voltage	24VAC	THT-EX1217*APE6*
	100VAC	THT-EX1217*BPE6*
	110VAC	THT-EX1217*CPE6*
	120VAC	THT-EX1217*FPE6*
	200VAC	THT-EX1217*DPE6*
	208VAC	THT-EX1217*GPE6*
	220VAC	THT-EX1217*EPE6*

Rated power	60W	THT-EX1217**PE61
	106W	THT-EX1217**PE6B
	110W	THT-EX1217**PE6A
	116W	THT-EX1217**PE6D
	120W	THT-EX1217**PE62

Thermal parameters

Ambient temperature range $-20^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$

Temperature class	T6	THT-EX1217*APE6*
	T5	THT-EX1217WEPE6*
		THT-EX1217CEPE6*(60Hz)
	T4	THT-EX1217CEPE6*(50Hz)

CONDITIONS OF CERTIFICATION: YES as shown below:

1. The M25 cable gland will be installed by end user, the rest unused holes shall be blocked by screw plug which comply with the requirements of standards IEC 60079-1 and IEC 60079-31.
2. The power cable will be installed by end user, and the end user can use the cable which is specified in the user manual only.
3. The end user must install earthing wire according to user manual before use.

Annex: [DE-IECEX_TUR_14.0028X_00_Attachment_rev.1.0.pdf](#)