

EU-TYPE EXAMINATION CERTIFICATE



Equipment or Protective System intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

EU-Type Examination Certificate Number: **UL 22 ATEX 2815X Rev. 1**

Product: **LED Luminaires, Models L1102D Series – Models THT-2LA*d5**1102 and THT-2KA*d5**1102 Series**

Manufacturer: **Top Hi-Tech Co., Ltd.**

Address: **9F, No. 1, Zhongshan Rd, Tucheng District, New Taipei City 236, Taiwan (R.O.C)**

This product and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

UL International Demko A/S, notified body number 0539 in accordance with Article 17 of the Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres, given in Annex II to the Directive.

The examination and test results are recorded in the confidential report no. **US/UL/ExTR22.0064/01.**

Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0:2018

EN 60079-1:2014

EN 60079-31:2014

Where additional criteria beyond those given here have been used, they are listed at item 18 in the Schedule

If the sign "X" is placed after the certificate number, it indicates that the product is subject to the "Specific Conditions of Use" listed under item 17 of this certificate.

This EU-Type Examination Certificate relates only to the technical design of the specified product in accordance to the Directive 2014/34/EU. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by the certificate.

The marking of the product shall include the following (marking is provided in the Schedule as a part of item 15, if applicable):



II 2 G Ex db IIC T5...T4 Gb



II 2 D Ex tb IIIC T95°C...T105°C Db

Certification Manager
Thomas Wilson

This is to certify that the sample(s) of the Product described herein ("Certified Product") has been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the ATEX Product Certification Program Requirements. This certificate and test results obtained apply only to the product sample(s) submitted by the Manufacturer. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured product. UL has not established Follow-Up Service or other surveillance of the product. The Manufacturer is solely and fully responsible for conformity of all product to all applicable Standards, specifications, requirements or Directives. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

Date of issue: 2023-02-17

Re-issued: 2025-12-11

Notified Body

UL International Demko A/S, Borupvang 5A, 2750 Ballerup, Denmark
Tel. +45 44 85 65 65, info.dk@ul.com, www.ul.com



Accredited by DANAK under registration number 7011 to certification of products.

This certificate may only be reproduced in its entirety and without any change. Information about previous revisions of this certificate can be requested by contacting info.dk@ul.com

Form-ULID-000217 (DCS:00-IC-F0056-1) – Issue 30.0

Page 1 of 4

[13]

[14]

[15]

Schedule

EU-TYPE EXAMINATION CERTIFICATE No.

UL 22 ATEX 2815X Rev. 1

Description of Product

The Model L1102D Series of LED luminaires is suitable for use in hazardous location classified as Zone 1 and Zone 21. This luminaire consists of one "db"/"tb" chamber. The enclosure material is aluminum alloy. The light-transmitting part is made of tempered glass. The gasket is used to maintain the IP rating. The entry for wiring through integral cable gland maintains the degree of protection.

Nomenclature for Luminaires:

The complete luminaire catalogue number example is as follows:

Cat.	THT	-	2L	A	100	d	5	2	C	1102
No.	1		2	3	4	5	6	7	8	9

1 – Brand name

THT = Top Hi-Tech Co., Ltd.

2 – Designates type of LED module

2L = COB type

2K = SMD type

3 – Designates type of material

A = ADC 12

4 – Designates wattage of luminaire

30W = 30W (For COB type and SMD LED module)

40W = 40W (For COB and SMD type LED module)

50W = 50W (For COB and SMD type LED module)

60W = 60W (For COB and SMD type LED module)

65W = 65W (For SMD type LED module only)

70W = 70W (For COB and SMD type LED module)

75W = 75W (For SMD type LED module only)

80W = 80W (For COB and SMD type LED module)

90W = 90W (For COB and SMD type LED module)

95W = 95W (For SMD type LED module only)

100 = 100W (For COB and SMD type LED module)

5 – Designates type of protection type

d = Ex d

6 – Sub-series designation

5 = Screw lock

7 – Designates voltage of luminaire

3 = 24 Vac (For COB type LED module only)

4 = 100 Vac (For COB type LED module only)

1 = 110 Vac (For COB and SMD type LED module)

6 = 120 Vac (For COB and SMD type LED module)

5 = 200 Vac (For COB type LED module only)

2 = 220 Vac (For COB and SMD type LED module)

D = 230 Vac (For COB and SMD type LED module)

9 = 277 Vac (For COB and SMD type LED module)

C = 480 Vac (For COB and SMD type LED module)

H = 100~277 Vac (For DC SMD type LED module only)

K = 24 Vdc (For DC SMD type LED module only)

8 – Designates CCT of LED

C = Cool white

W = Warm white

9 – Model name

1102 = Model L1102D Series



Accredited by DANAK under registration number 7011 to certification of products.

This certificate may only be reproduced in its entirety and without any change. Information about previous revisions of this certificate can be requested by contacting info.dk@ul.com

Form-ULID-000217 (DCS:00-IC-F0056-1) – Issue 30.0

Page 2 of 4

[13]

[14]

Schedule

EU-TYPE EXAMINATION CERTIFICATE No.

UL 22 ATEX 2815X Rev. 1

Models covered are as follows:

Models	Ambient Temperature range	Gas Temperature Code	Dust Temperature Rating
THT-2LAxd5yz1102	-20°C to +40°C	T5	T95°C
	-20°C to +50°C	T4	T105°C
THT-2KAxxd5yyz1102	-20°C to +40°C	T5	T95°C
	-20°C to +50°C	T4	T105°C
THT-2KAxxxd5Hz1102	-20°C to +40°C	T5	T95°C
	-20°C to +50°C	T4	T105°C
THT-2KAxxxxd5Kz1102	-20°C to +40°C	T5	T95°C
	-20°C to +50°C	T4	T105°C

x can be 30W, 40W, 50W, 60W, 70W, 80W, 90W or 100;
 y can be 3, 4, 1, 6, 5, 2, D, 9 or C;
 z can be C or W;
 xx can be 40W, 50W, 60W, 65W, 75W or 95W;
 yy can be 1, 6, 2, D, 9 or C;
 xxx can be 30W, 40W, 50W, 60W, 65W, 70W, 75W, 80W, 90W, 95W or 100;
 xxxx can be 60W, 80W or 100;

The optical radiation output of the product with respect to explosion protection, according to Annex II clause 1.3.1 of the Directive 2014/34/EU is not covered in this certificate.

Electrical data

Models	Frequency (Hz)	Voltage (Vac)	Wattage (W)
THT-2LA30Wd5yz1102	50/60	24/100/110/120/200/220/230/277/480	30 W
THT-2LA40Wd5yz1102	50/60	24/100/110/120/200/220/230/277/480	40 W
THT-2LA50Wd5yz1102	50/60	24/100/110/120/200/220/230/277/480	50 W
THT-2LA60Wd5yz1102	50/60	24/100/110/120/200/220/230/277/480	60 W
THT-2LA70Wd5yz1102	50/60	24/100/110/120/200/220/230/277/480	70 W
THT-2LA80Wd5yz1102	50/60	24/100/110/120/200/220/230/277/480	80 W
THT-2LA90Wd5yz1102	50/60	24/100/110/120/200/220/230/277/480	90 W
THT-2LA100d5yz1102	50/60	24/100/110/120/200/220/230/277/480	100 W
THT-2KA40Wd5yyz1102	50/60	110/120/220/230/277/480	40W
THT-2KA50Wd5yyz1102	50/60	110/120/220/230/277/480	50W
THT-2KA60Wd5yyz1102	50/60	110/120/220/230/277/480	60W
THT-2KA65Wd5yyz1102	50/60	110/120/220/230/277/480	65W
THT-2KA75Wd5yyz1102	50/60	110/120/220/230/277/480	75W
THT-2KA95Wd5yyz1102	50/60	110/120/220/230/277/480	95W
THT-2KA30Wd5Hz1102	50/60	100~277	30W
THT-2KA40Wd5Hz1102	50/60	100~277	40W
THT-2KA50Wd5Hz1102	50/60	100~277	50W
THT-2KA60Wd5Hz1102	50/60	100~277	60W
THT-2KA65Wd5Hz1102	50/60	100~277	65W
THT-2KA70Wd5Hz1102	50/60	100~277	70W
THT-2KA75Wd5Hz1102	50/60	100~277	75W
THT-2KA80Wd5Hz1102	50/60	100~277	80W
THT-2KA90Wd5Hz1102	50/60	100~277	90W
THT-2KA95Wd5Hz1102	50/60	100~277	95W
THT-2KA100d5Hz1102	50/60	100~277	100W
THT-2KA60Wd5Kz1102	-	24 (Vdc)	60W
THT-2KA80Wd5Kz1102	-	24 (Vdc)	80W
THT-2KA100d5Kz1102	-	24 (Vdc)	100W

y can be 3, 4, 1, 6, 5, 2, D, 9 or C;
 z can be C or W;
 yy can be 1, 6, 2, D, 9 or C;

Routine tests

Routine overpressure tests in accordance with EN 60079-1:2014 shall be conducted on all units in accordance with clause 15.2.3.2, at a pressure of 10.76 bar (156 psi) for a duration of not less than 10 seconds. There shall be no sign of damage, deformation or rupture that will invalidate the concept of protection.

[16]

Descriptive Documents

The scheduled drawings are listed in the report no. provided under item no. [8] on page 1 of this EU-Type Examination Certificate.



Accredited by DANAK under registration number 7011 to certification of products.

This certificate may only be reproduced in its entirety and without any change. Information about previous revisions of this certificate can be requested by contacting info.dk@ul.com

Form-ULID-000217 (DCS:00-IC-F0056-1) – Issue 30.0

Page 3 of 4

[13]

Schedule

[14]

EU-TYPE EXAMINATION CERTIFICATE No. UL 22 ATEX 2815X Rev. 1

[17]

Specific conditions of use:

- Do not open when an explosive atmosphere is present.
- Do not open when energized.
- The flameproof joints are not intended to be disassembled or repaired.
- Potential electrostatic charging hazard and cable rating– see instructions.
- The special fastener shall have a property class of A2-70.

[18]

Essential Health and Safety Requirements

The Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9.

Additional information

The Model L1102D Series has in addition passed the tests for Ingress Protection to IP67 in accordance with EN60529:1991+A1:2000+A2:2013.

The manufacturer shall inform the notified body concerning all modifications to the technical documentation as described in Annex III to Directive 2014/34/EU of the European Parliament and the Council of 26 February 2014.